



**NOTES:**

1. THE METER SETTER MUST BE EQUAL DISTANCE FROM THE LONGITUDINAL SIDES OF THE METER BOX. THE TOP OF THE METER SETTER MUST BE 6" BELOW THE BOTTOM OF THE METER BOX LID. THE METER SETTER MUST BE BETWEEN 3" AND 4" FROM THE LATITUDINAL END OF THE METER BOX AND MUST BE VERTICAL (90°) TO GROUND LEVEL.
2. THE METER SETTER MUST REMAIN IN A VERTICAL POSITION AFTER THE CONNECTION TO THE CUSTOMER'S LINE HAS BEEN COMPLETED.
3. THE METER BOX MUST REMAIN FREE OF FOREIGN MATERIAL SUCH AS CONCRETE & DEBRIS.
4. METER BOX SUPPLIED BY DEVELOPER/CONTRACTOR. METER BOX SHALL BE PER STANDARD DETAIL W-18.
6. INCLUDE 14 GAUGE SOLID CORE COATED TRACER WIRE FROM WATER MAIN TO METER BOX. INCLUDE 2-FT OF ADDITIONAL WIRE IN METER BOX.



## METER INSTALLATION

REVISION DATE APRIL 11, 2023	SCALE NTS	DISTRICT APPROVAL <i>Gregory G. Hill, P.E.</i>	DATE APPROVED APRIL 27, 2023
FILE NAME W-19.DWG		DWG. NO.	W-19