



**ELEVATION**

**NOTE:**

MAXIMUM DEFLECTION PER JOINT NOT OVER 2" PER FOOT, OR 5" PER STANDARD 30" PIPE SECTION. (NOT TO EXCEED PIPE MANUFACTURER'S SPECIFICATIONS)



**STANDARD PLAN STUB SERVICE  
(ALT. NO. 1)**

REVISION DATE MAY 17, 2011	SCALE NTS	DISTRICT APPROVAL Gregory G. Hill, P.E.	DATE APPROVED APRIL 18, 2023
FILE NAME S-5.DWG		DWG. NO.	S-5